



**Prince of Songkla University  
Faculty of Engineering**

**Midterm Test**  
**29 December 2007**  
**215-231 Thermodynamics II**

**Semester 2/2550**  
**9:00 – 12:00**  
**Room: A 400**

Name _____	ID _____
------------	----------

**Direction:**

1. All types of calculator, and dictionary are permitted.
2. There are totally 6 problems

**Gumpon Prateepchailul**  
**Instructor**


<b>Problem No.</b>	<b>Full score</b>	<b>Your mark</b>
1	10	
2	15	
3	15	
4	25	
5	15	
6	25	
<b>Total</b>	<b>105</b>	

Name \_\_\_\_\_ ID \_\_\_\_\_

- 1) A classroom that normally contains 40 people is to be air-conditioned with window air-conditioning units of 5 kW cooling capacity. A person at rest may be assumed to dissipate heat at a rate of about 360 kJ/h. There are 10 light bulbs in the room, each with a rating of 100 W. The rate of the heat transfer to the classroom through the walls and the windows is estimated to be 15,000 kJ/h. If the room air is to be maintained at a constant temperature of  $21^{\circ}\text{C}$ , determine the number of window air-conditioning units required. (10 marks)


Name \_\_\_\_\_ ID \_\_\_\_\_

- 2) The radiator of a steam heating system has a volume of 20 L and is filled with superheated vapour at 300 kPa and 250 °C. At this moment both the inlet and exit valves to the radiator are closed. Determine the amount of heat that will be transferred to the room when the steam pressure drops to 100 kPa. Also show the process on a P-v diagram with respect to saturation line. 15 marks)



Name \_\_\_\_\_ ID \_\_\_\_\_

- 3) Air is compressed by a 12-kW compressor from  $P_1$  to  $P_2$ . The air temperature is maintained constant at  $25^\circ C$  during this process as a result of heat transfer to the surrounding medium at  $10^\circ C$ . Determine the rate of entropy change of the air. State the assumptions made in solving this problem. (15 marks)



Name \_\_\_\_\_ ID \_\_\_\_\_


- 4) Air is compressed in a piston-cylinder device from 100 kPa and  $17^{\circ}\text{C}$  to 800 kPa in a reversible, adiabatic process. Determine the final temperature and the work done during this process, assuming (a) constant specific heats (b) variable specific heats for air. (25 marks)

Name \_\_\_\_\_ ID \_\_\_\_\_

- 5) A heat engine receives heat from a source at 1500 K at a rate of 700 kJ/s, and it rejects the waste heat to a medium at 320 K. The measured power output of the heat engine is 320 K, and the environment temperature is 25°C. Determine (a) the reversible power (b) the rate of irreversibility and (c) the second law efficiency of this heat engine. (15 marks)

Name \_\_\_\_\_ ID \_\_\_\_\_

- 6) Steam enters an adiabatic turbine at 6 MPa,  $600^{\circ}\text{C}$ , and 80 m/s and leaves at 50 kPa,  $100^{\circ}\text{C}$  and 140 m/s. If the power output of the turbine is 5 MW, determine (a) the reversible power output and (b) the second law efficiency of the turbine. Assume the surroundings to be at  $25^{\circ}\text{C}$ . (25 marks)



Name \_\_\_\_\_ ID \_\_\_\_\_

Molar mass, gas constant, and critical-point properties

Substance	Formula	Molar mass, <i>M</i> kg/kmol	Gas constant, <i>R</i> kJ/kg · K*	Critical-point properties		
				Tempera- ture, K	Pressure, MPa	Volume, m <sup>3</sup> /kmol
Air	—	28.97	0.2870	132.5	3.77	0.0883
Ammonia	NH <sub>3</sub>	17.03	0.4882	405.5	11.28	0.0724
Argon	Ar	39.948	0.2081	151	4.86	0.0749
Benzene	C <sub>6</sub> H <sub>6</sub>	78.115	0.1064	562	4.92	0.1603
Bromine	Br <sub>2</sub>	159.808	0.0520	584	10.34	0.1355
<i>n</i> -Butane	C <sub>4</sub> H <sub>10</sub>	58.124	0.1430	425.2	3.80	0.1547
Carbon dioxide	CO <sub>2</sub>	44.01	0.1889	304.2	7.39	0.0943
Carbon monoxide	CO	28.011	0.2968	133	3.50	0.0930
Carbon tetrachloride	CCl <sub>4</sub>	153.82	0.05405	556.4	4.56	0.1759
Chlorine	Cl <sub>2</sub>	70.906	0.1173	417	7.71	0.1242
Chloroform	CHCl <sub>3</sub>	119.38	0.06964	536.6	5.47	0.1403
Dichlorodifluoromethane (R-12)	CCl <sub>2</sub> F <sub>2</sub>	120.91	0.06876	384.7	4.01	0.1179
Dichlorofluoromethane (R-21)	CHCl <sub>2</sub> F	102.92	0.08078	451.7	5.17	0.1973
Ethane	C <sub>2</sub> H <sub>6</sub>	30.070	0.2765	305.5	4.48	0.1480
Ethyl alcohol	C <sub>2</sub> H <sub>5</sub> OH	46.07	0.1805	516	6.38	0.1673
Ethylene	C <sub>2</sub> H <sub>4</sub>	28.054	0.2964	282.4	5.12	0.1242
Helium	He	4.003	2.0769	5.3	0.23	0.0578
<i>n</i> -Hexane	C <sub>6</sub> H <sub>14</sub>	86.179	0.09647	507.9	3.03	0.1677
Hydrogen (normal)	H <sub>2</sub>	2.016	4.1240	33.3	1.30	0.0649
Krypton	Kr	83.80	0.09921	209.4	5.50	0.1924
Methane	CH <sub>4</sub>	16.043	0.5182	191.1	4.64	0.0993
Methyl alcohol	CH <sub>3</sub> OH	32.042	0.2595	513.2	7.95	0.1180
Methyl chloride	CH <sub>3</sub> Cl	50.488	0.1647	416.3	6.68	0.1430
Neon	Ne	20.183	0.4119	44.5	2.73	0.0417
Nitrogen	N <sub>2</sub>	28.013	0.2968	126.2	3.39	0.0899
Nitrous oxide	N <sub>2</sub> O	44.013	0.1889	309.7	7.27	0.0961
Oxygen	O <sub>2</sub>	31.999	0.2598	154.8	5.08	0.0780
Propane	C <sub>3</sub> H <sub>8</sub>	44.097	0.1885	370	4.26	0.1998
Propylene	C <sub>3</sub> H <sub>6</sub>	42.081	0.1976	365	4.62	0.1810
Sulfur dioxide	SO <sub>2</sub>	64.063	0.1298	430.7	7.88	0.1217
Tetrafluoroethane (R-134a)	CF <sub>3</sub> CH <sub>2</sub> F	102.03	0.08149	374.3	4.067	0.1847
Trichlorofluoromethane (R-11)	CCl <sub>3</sub> F	137.37	0.06052	471.2	4.38	0.2478
Water	H <sub>2</sub> O	18.015	0.4615	647.3	22.09	0.0568
Xenon	Xe	131.30	0.06332	289.8	5.88	0.1186

\*The unit kJ/kg · K is equivalent to kPa · m<sup>3</sup>/kg · K. The gas constant is calculated from  $R = R_u/M$ , where  $R_u = 8.314 \text{ kJ/kmol} \cdot \text{K}$  and  $M$  is the molar mass.

Source: K. A. Kobe and R. E. Lynn, Jr., *Chemical Review* 52 (1953), pp. 117–236; and ASHRAE, *Handbook of Fundamentals* (Atlanta, GA: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1993), pp. 16.4 and 36.1.

## Ideal-gas specific heats of various common gases

(a) At 300 K

Gas	Formula	Gas constant, $R$ kJ/kg · K	$C_p$ kJ/kg · K	$C_v$ kJ/kg · K	$k$
Air	—	0.2870	1.005	0.718	1.400
Argon	Ar	0.2081	0.5203	0.3122	1.667
Butane	$C_4H_{10}$	0.1433	1.7164	1.5734	1.091
Carbon dioxide	$CO_2$	0.1889	0.846	0.657	1.289
Carbon monoxide	CO	0.2968	1.040	0.744	1.400
Ethane	$C_2H_6$	0.2765	1.7662	1.4897	1.186
Ethylene	$C_2H_4$	0.2964	1.5482	1.2518	1.237
Helium	He	2.0769	5.1926	3.1156	1.667
Hydrogen	$H_2$	4.1240	14.307	10.183	1.405
Methane	$CH_4$	0.5182	2.2537	1.7354	1.299
Neon	Ne	0.4119	1.0299	0.6179	1.667
Nitrogen	$N_2$	0.2968	1.039	0.743	1.400
Octane	$C_8H_{18}$	0.0729	1.7113	1.6385	1.044
Oxygen	$O_2$	0.2598	0.918	0.658	1.395
Propane	$C_3H_8$	0.1885	1.6794	1.4909	1.126
Steam	$H_2O$	0.4615	1.8723	1.4108	1.327

Note: The unit kJ/kg · K is equivalent to kJ/kg · °C.

Source: Gordon J. Van Wylen and Richard E. Sonntag, *Fundamentals of Classical Thermodynamics*, English/SI Version, 3rd ed. (New York: John Wiley & Sons, 1986), p. 687, Table A.8SI.

82  
THERMODYNAMICS

Ideal-gas specific heats of various common gases (Continued)

(b) At various temperatures

Temperature, K	$C_p$ kJ/kg · K	$C_v$ kJ/kg · K	$k$	$C_p$ kJ/kg · K	$C_v$ kJ/kg · K	$k$	$C_p$ kJ/kg · K	$C_v$ kJ/kg · K	$k$
	Air			Carbon dioxide, $CO_2$			Carbon monoxide, $CO$		
250	1.003	0.716	1.401	0.791	0.602	1.314	1.039	0.743	1 400
300	1.005	0.718	1.400	0.846	0.657	1.288	1.040	0.744	1 399
350	1.008	0.721	1.398	0.895	0.706	1.268	1.043	0.746	1 398
400	1.013	0.726	1.395	0.939	0.750	1.252	1.047	0.751	1 395
450	1.020	0.733	1.391	0.978	0.790	1.239	1.054	0.757	1 392
500	1.029	0.742	1.387	1.014	0.825	1.229	1.063	0.767	1 387
550	1.040	0.753	1.381	1.046	0.857	1.220	1.075	0.778	1 382
600	1.051	0.764	1.376	1.075	0.886	1.213	1.087	0.790	1 376
650	1.063	0.776	1.370	1.102	0.913	1.207	1.100	0.803	1 370
700	1.075	0.788	1.364	1.126	0.937	1.202	1.113	0.816	1 364
750	1.087	0.800	1.359	1.148	0.959	1.197	1.126	0.829	1 358
800	1.099	0.812	1.354	1.169	0.980	1.193	1.139	0.842	1 353
900	1.121	0.834	1.344	1.204	1.015	1.186	1.163	0.866	1 343
1000	1.142	0.855	1.336	1.234	1.045	1.181	1.185	0.888	1 335
<i>Hydrogen, <math>H_2</math></i>				<i>Nitrogen, <math>N_2</math></i>			<i>Oxygen, <math>O_2</math></i>		
250	14.051	9.927	1.416	1.039	0.742	1.400	0.913	0.653	1 398
300	14.307	10.183	1.405	1.039	0.743	1.400	0.918	0.658	1 395
350	14.427	10.302	1.400	1.041	0.744	1.399	0.928	0.668	1 389
400	14.476	10.352	1.398	1.044	0.747	1.397	0.941	0.681	1 382
450	14.501	10.377	1.398	1.049	0.752	1.395	0.956	0.696	1 373
500	14.513	10.389	1.397	1.056	0.759	1.391	0.972	0.712	1 365
550	14.530	10.405	1.396	1.065	0.768	1.387	0.988	0.728	1 358
600	14.546	10.422	1.396	1.075	0.778	1.382	1.003	0.743	1 350
650	14.571	10.447	1.395	1.086	0.789	1.376	1.017	0.758	1 343
700	14.604	10.480	1.394	1.098	0.801	1.371	1.031	0.771	1 337
750	14.645	10.521	1.392	1.110	0.813	1.365	1.043	0.783	1 332
800	14.695	10.570	1.390	1.121	0.825	1.360	1.054	0.794	1 327
900	14.822	10.698	1.385	1.145	0.849	1.349	1.074	0.814	1 319
1000	14.983	10.859	1.380	1.167	0.870	1.341	1.090	0.830	1 313

Source: Kenneth Wark, *Thermodynamics*, 4th ed. (New York: McGraw-Hill, 1983), p. 783, Table A-4M. Originally published in *Tables of Thermal Properties of Gases*, NBS Circular 564, 1955.

Idea  
(c) I

Sub  
Nit  
Oxy  
Air  
Hyd  
Cart  
Cart  
Wat  
Nit  
Nit  
Nit  
Am  
Sul  
Sul  
Sul  
Act  
Ber  
Me  
Eth  
Hy  
Me  
Eth  
Pr  
n-  
i-E  
n-  
n-  
n-  
n-  
Sou

**THERMODYNAMICS**

**H<sub>2</sub>O**

Saturated water—Pressure table

Press., P kPa	Specific volume, m <sup>3</sup> /kg			Internal energy, kJ/kg			Enthalpy, kJ/kg			Entropy, kJ/kg · K		
	Sat. temp., <i>T<sub>sat</sub></i> °C	Sat. liquid, <i>v<sub>f</sub></i>	Sat. vapor, <i>v<sub>g</sub></i>	Sat. liquid, <i>u<sub>f</sub></i>	Evap., <i>u<sub>fg</sub></i>	Sat. vapor, <i>u<sub>g</sub></i>	Sat. liquid, <i>h<sub>f</sub></i>	Evap., <i>h<sub>fg</sub></i>	Sat. vapor, <i>h<sub>g</sub></i>	Sat. liquid, <i>s<sub>f</sub></i>	Evap., <i>s<sub>fg</sub></i>	Sat. vapor, <i>s</i>
0.6113	0.01	0.001000	206.14	0.00	2375.3	2375.3	0.01	2501.3	2501.4	0.0000	9.1562	9 1562
1.0	6.98	0.001000	129.21	29.30	2355.7	2385.0	29.30	2484.9	2514.2	0.1059	8.8697	8 9756
1.5	13.03	0.001001	87.98	54.71	2338.6	2393.3	54.71	2470.6	2525.3	0.1957	8.6322	8 8279
2.0	17.50	0.001001	67.00	73.48	2326.0	2399.5	73.48	2460.0	2533.5	0.2607	8.4629	8 7237
2.5	21.08	0.001002	54.25	88.48	2315.9	2404.4	88.49	2451.6	2540.0	0.3120	8.3311	8 6432
3.0	24.08	0.001003	45.67	101.04	2307.5	2408.5	101.05	2444.5	2545.5	0.3545	8.2231	8 5776
4.0	28.96	0.001004	34.80	121.45	2293.7	2415.2	121.46	2432.9	2554.4	0.4226	8.0520	8 4746
5.0	32.88	0.001005	28.19	137.81	2282.7	2420.5	137.82	2423.7	2561.5	0.4764	7.9187	8 3951
7.5	40.29	0.001008	19.24	168.78	2261.7	2430.5	168.79	2406.0	2574.8	0.5764	7.6750	8 2515
10	45.81	0.001010	14.67	191.82	2246.1	2437.9	191.83	2392.8	2584.7	0.6493	7.5009	8 1502
15	53.97	0.001014	10.02	225.92	2222.8	2448.7	225.94	2373.1	2599.1	0.7549	7.2536	8 0085
20	60.06	0.001017	7.649	251.38	2205.4	2456.7	251.40	2358.3	2609.7	0.8320	7.0766	7 9085
25	64.97	0.001020	6.204	271.90	2191.2	2463.1	271.93	2346.3	2618.2	0.8931	6.9383	7 8314
30	69.10	0.001022	5.229	289.20	2179.2	2468.4	289.23	2336.1	2625.3	0.9439	6.8247	7 7686
40	75.87	0.001027	3.993	317.53	2159.5	2477.0	317.58	2319.2	2636.8	1.0259	6.6441	7 6700
50	81.33	0.001030	3.240	340.44	2143.4	2483.9	340.49	2305.4	2645.9	1.0910	6.5029	7 5939
75	91.78	0.001037	2.217	384.31	2112.4	2496.7	384.39	2278.6	2663.0	1.2130	6.2434	7 4564
Press., MPa												
0.100	99.63	0.001043	1.6940	417.36	2088.7	2506.1	417.46	2258.0	2675.5	1.3026	6.0568	7 3594
0.125	105.99	0.001048	1.3749	444.19	2069.3	2513.5	444.32	2241.0	2685.4	1.3740	5.9104	7 2844
0.150	111.37	0.001053	1.1593	466.94	2052.7	2519.7	467.11	2226.5	2693.6	1.4336	5.7897	7 2233
0.175	116.06	0.001057	1.0036	486.80	2038.1	2524.9	486.99	2213.6	2700.6	1.4849	5.6868	7 1717
0.200	120.23	0.001061	0.8857	504.49	2025.0	2529.5	504.70	2201.9	2706.7	1.5301	5.5970	7 1271
0.225	124.00	0.001064	0.7933	520.47	2013.1	2533.6	520.72	2191.3	2712.1	1.5706	5.5173	7 0878
0.250	127.44	0.001067	0.7187	535.10	2002.1	2537.2	535.37	2181.5	2716.9	1.6072	5.4455	7 0527
0.275	130.60	0.001070	0.6573	548.59	1991.9	2540.5	548.89	2172.4	2721.3	1.6408	5.3801	7 0209
0.300	133.55	0.001073	0.6058	561.15	1982.4	2543.6	561.47	2163.8	2725.3	1.6718	5.3201	6 9919
0.325	136.30	0.001076	0.5620	572.90	1973.5	2546.4	573.25	2155.8	2729.0	1.7006	5.2646	6 9652
0.350	138.88	0.001079	0.5243	583.95	1965.0	2548.9	584.33	2148.1	2732.4	1.7275	5.2130	6 9405
0.375	141.32	0.001081	0.4914	594.40	1956.9	2551.3	594.81	2140.8	2735.6	1.7528	5.1647	6 9175
0.40	143.63	0.001084	0.4625	604.31	1949.3	2553.6	604.74	2133.8	2738.6	1.7766	5.1193	6 8959
0.45	147.93	0.001088	0.4140	622.77	1934.9	2557.6	623.25	2120.7	2743.9	1.8207	5.0359	6 8565
0.50	151.86	0.001093	0.3749	639.68	1921.6	2561.2	640.23	2108.5	2748.7	1.8607	4.9606	6 8213
0.55	155.48	0.001097	0.3427	655.32	1909.2	2564.5	665.93	2097.0	2753.0	1.8973	4.8920	6 7893
0.60	158.85	0.001101	0.3157	669.90	1897.5	2567.4	670.56	2086.3	2756.8	1.9312	4.8288	6 7600
0.65	162.01	0.001104	0.2927	683.56	1886.5	2570.1	684.28	2076.0	2760.3	1.9627	4.7703	6 7331
0.70	164.97	0.001108	0.2729	696.44	1876.1	2572.5	697.22	2066.3	2763.5	1.9922	4.7158	6 7080
0.75	167.78	0.001112	0.2556	708.64	1866.1	2574.7	709.47	2057.0	2766.4	2.0200	4.6647	6 6847
0.80	170.43	0.001115	0.2404	720.22	1856.6	2576.8	721.11	2048.0	2769.1	2.0462	4.6166	6 6628
0.85	172.96	0.001118	0.2270	731.27	1847.4	2578.7	732.22	2039.4	2771.6	2.0710	4.5711	6 6421
0.90	175.38	0.001121	0.2150	741.83	1838.6	2580.5	742.83	2031.1	2773.9	2.0946	4.5280	6 6226
0.95	177.69	0.001124	0.2042	751.95	1830.2	2582.1	753.02	2023.1	2776.1	2.1172	4.4869	6 6041
1.00	179.91	0.001127	0.19444	761.68	1822.0	2583.6	762.81	2015.3	2778.1	2.1387	4.4478	6 5865
1.10	184.09	0.001133	0.17753	780.09	1806.3	2586.4	781.34	2000.4	2781.7	2.1792	4.3744	6 5536
1.20	187.99	0.001139	0.16333	797.29	1791.5	2588.8	798.65	1986.2	2784.8	2.2166	4.3067	6 5233
1.30	191.64	0.001144	0.15125	813.44	1777.5	2591.0	814.93	1972.7	2787.6	2.2515	4.2438	6 4953

334  
THERMODYNAMICS

H<sub>2</sub>O

Superheated water

T °C	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K
<i>P</i> = 0.01 MPa (45.81°C)*					<i>P</i> = 0.05 MPa (81.33°C)				<i>P</i> = 0.10 MPa (99.63°C)			
Sat. <sup>†</sup>	14.674	2437.9	2584.7	8.1502	3.240	2483.9	2645.9	7.5939	1.6940	2506.1	2675.5	7.3594
50	14.869	2443.9	2592.6	8.1749	3.418	2511.6	2682.5	7.6947	1.6958	2506.7	2676.2	7.3514
100	17.196	2515.5	2687.5	8.4479	3.889	2585.6	2780.1	7.9401	1.9364	2582.8	2776.4	7.6134
150	19.512	2587.9	2783.0	8.6882	4.356	2659.9	2877.7	8.1580	2.172	2658.1	2875.3	7.8343
200	21.825	2661.3	2879.5	8.9038	4.820	2735.0	2976.0	8.3556	2.406	2733.7	2974.3	8.0333
250	24.136	2736.0	2977.3	9.1002	5.284	2811.3	3075.5	8.5373	2.639	2810.4	3074.3	8.2158
300	26.445	2812.1	3076.5	9.2813	6.209	2968.5	3278.9	8.8642	3.103	2967.9	3278.2	8.5435
400	31.063	2968.9	3279.6	9.6077	7.134	3132.0	3488.7	9.1546	3.565	3131.6	3488.1	8.8342
500	35.679	3132.3	3489.1	9.8978	8.057	3302.2	3705.1	9.4178	4.028	3301.9	3704.4	9.0976
600	40.295	3302.5	3705.4	10.1608	8.981	3479.4	3928.5	9.6599	4.490	3479.2	3928.2	9.3398
700	44.911	3479.6	3928.7	10.4028	9.904	3663.6	4158.9	9.8852	4.952	3663.5	4158.6	9.5552
800	49.526	3663.8	4159.0	10.6281	10.828	3854.9	4396.3	10.0967	5.414	3854.8	4396.1	9.7767
900	54.141	3855.0	4396.4	10.8396	11.751	4052.9	4640.5	10.2964	5.875	4052.8	4640.3	9.9764
1000	58.757	4053.0	4640.6	11.0393	12.674	4257.4	4891.1	10.4859	6.337	4257.3	4891.0	10.1559
1100	63.372	4257.5	4891.2	11.2287	13.597	4467.8	5147.7	10.6662	6.799	4467.7	5147.6	10.3463
1200	67.987	4467.9	5147.8	11.4091	14.521	4683.6	5409.6	10.8382	7.260	4683.5	5409.5	10.5183
<i>P</i> = 0.20 MPa (120.23°C)					<i>P</i> = 0.30 MPa (133.55°C)				<i>P</i> = 0.40 MPa (143.63°C)			
Sat.	0.8857	2529.5	2706.7	7.1272	0.6058	2543.6	2725.3	6.9919	0.4625	2553.6	2738.6	6.8959
150	0.9596	2576.9	2768.8	7.2795	0.6339	2570.8	2761.0	7.0778	0.4708	2564.5	2752.8	6.9299
200	1.0803	2654.4	2870.5	7.5066	0.7163	2650.7	2865.6	7.3115	0.5342	2646.8	2860.5	7.1706
250	1.1988	2731.2	2971.0	7.7086	0.7964	2728.7	2967.6	7.5166	0.5951	2726.1	2964.2	7.3789
300	1.3162	2808.6	3071.8	7.8926	0.8753	2806.7	3069.3	7.7022	0.6548	2804.8	3066.8	7.5662
400	1.5493	2966.7	3276.6	8.2218	1.0315	2965.6	3275.0	8.0330	0.7726	2964.4	3273.4	7.8985
500	1.7814	3130.8	3487.1	8.5133	1.1867	3130.0	3486.0	8.3251	0.8893	3129.2	3484.9	8.1913
600	2.013	3301.4	3704.0	8.7770	1.3414	3300.8	3703.2	8.5892	1.0055	3300.2	3702.4	8.4558
700	2.244	3478.8	3927.6	9.0194	1.4957	3478.4	3927.1	8.8319	1.1215	3477.9	3926.5	8.6987
800	2.475	3663.1	4158.2	9.2449	1.6499	3662.9	4157.8	9.0576	1.2372	3662.4	4157.3	8.9244
900	2.705	3854.5	4395.8	9.4566	1.8041	3854.2	4395.4	9.2692	1.3529	3853.9	4395.1	9.1362
1000	2.937	4052.5	4640.0	9.6563	1.9581	4052.3	4639.7	9.4690	1.4685	4052.0	4639.4	9.3360
1100	3.168	4257.0	4890.7	9.8458	2.1121	4256.8	4890.4	9.6585	1.5840	4256.5	4890.2	9.5256
1200	3.399	4467.5	5147.5	10.0262	2.2661	4467.2	5147.1	9.8389	1.6996	4467.0	5146.8	9.1060
1300	3.630	4683.2	5409.3	10.1982	2.4201	4683.0	5409.0	10.0110	1.8151	4682.8	5408.8	9.8780
<i>P</i> = 0.50 MPa (151.86°C)					<i>P</i> = 0.60 MPa (158.85°C)				<i>P</i> = 0.80 MPa (170.43°C)			
Sat.	0.3749	2561.2	2748.7	6.8213	0.3157	2567.4	2756.8	6.7600	0.2404	2576.8	2769.1	6.6628
200	0.4249	2642.9	2855.4	7.0592	0.3520	2638.9	2850.1	6.9665	0.2608	2630.6	2839.3	6.8158
250	0.4744	2723.5	2960.7	7.2709	0.3938	2720.9	2957.2	7.1816	0.2931	2715.5	2950.0	7.0384
300	0.5226	2802.9	3064.2	7.4599	0.4344	2801.0	3061.6	7.3724	0.3241	2797.2	3056.5	7.2328
350	0.5701	2882.6	3167.7	7.6329	0.4742	2881.2	3165.7	7.5464	0.3544	2878.2	3161.7	7.4089
400	0.6173	2963.2	3271.9	7.7938	0.5137	2962.1	3270.3	7.7079	0.3843	2959.7	3267.1	7.5716
500	0.7109	3128.4	3483.9	8.0873	0.5920	3127.6	3482.8	8.0021	0.4433	3126.0	3480.6	7.8673
600	0.8041	3299.6	3701.7	8.3522	0.6697	3299.1	3700.9	8.2674	0.5018	3297.9	3699.4	8.1333
700	0.8969	3477.5	3925.9	8.5952	0.7472	3477.0	3925.3	8.5107	0.5601	3476.2	3924.2	8.1770
800	0.9896	3662.1	4156.9	8.8211	0.8245	3661.8	4156.5	8.7367	0.6181	3661.1	4155.6	8.0033
900	1.0822	3853.6	4394.7	9.0329	0.9017	3853.4	4394.4	8.9486	0.6761	3852.8	4393.7	8.1153
1000	1.1747	4051.8	4639.1	9.2328	0.9788	4051.5	4638.8	9.1485	0.7340	4051.0	4638.2	9.0153
1100	1.2672	4256.3	4889.9	9.4224	1.0559	4256.1	4889.6	9.3381	0.7919	4255.6	4889.1	9.0050
1200	1.3596	4466.8	5146.6	9.6029	1.1330	4466.5	5146.3	9.5185	0.8497	4466.1	5145.9	9.1855
1300	1.4521	4682.5	5408.6	9.7749	1.2101	4682.3	5408.3	9.6906	0.9076	4681.8	5407.9	9.5575

\*The temperature in parentheses is the saturation temperature at the specified pressure.

<sup>†</sup>Properties of saturated vapor at the specified pressure.



## THERMODYNAMICS

H<sub>2</sub>O

### Superheated water (Continued)

T °C	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m <sup>3</sup> /kg	u kJ/kg	h kJ/kg	s kJ/kg · K
<i>P</i> = 4.0 MPa (250.40°C)					<i>P</i> = 4.5 MPa (257.49°C)					<i>P</i> = 5.0 MPa (263.99°C)		
Sat.	0.04978	2602.3	2801.4	6.0701	0.04406	2600.1	2798.3	6.0198	0.03944	2597.1	2794.3	5.9734
275	0.05457	2667.9	2886.2	6.2285	0.04730	2650.3	2863.2	6.1401	0.04141	2631.3	2838.3	6.0544
300	0.05884	2725.3	2960.7	6.3615	0.05135	2712.0	2943.1	6.2828	0.04532	2698.0	2924.5	6.2084
350	0.06645	2826.7	3092.5	6.5821	0.05840	2817.8	3080.6	6.5131	0.05194	2808.7	3068.4	6.4193
400	0.07341	2919.9	3213.6	6.7690	0.06475	2913.3	3204.7	6.7047	0.05781	2906.6	3195.7	6.6159
450	0.08002	3010.2	3330.3	6.9363	0.07074	3005.0	3323.3	6.8746	0.06330	2999.7	3316.2	6.8186
500	0.08643	3099.5	3445.3	7.0901	0.07651	3095.3	3439.6	7.0301	0.06857	3091.0	3433.8	6.9759
600	0.09885	3279.1	3674.4	7.3688	0.08765	3276.0	3670.5	7.3110	0.07869	3273.0	3666.5	7.2589
700	0.11095	3462.1	3905.9	7.6198	0.09847	3459.9	3903.0	7.5631	0.08849	3457.6	3900.1	7.5122
800	0.12287	3650.0	4141.5	7.8502	0.10911	3648.3	4139.3	7.7942	0.09811	3646.6	4137.1	7.7140
900	0.13469	3843.6	4382.3	8.0647	0.11965	3842.2	4380.6	8.0091	0.10762	3840.7	4378.8	7.9593
1000	0.14645	4042.9	4628.7	8.2662	0.13013	4041.6	4627.2	8.2108	0.11707	4040.4	4625.7	8.1512
1100	0.15817	4248.0	4880.6	8.4567	0.14056	4246.8	4879.3	8.4015	0.12648	4245.6	4878.0	8.3520
1200	0.16987	4458.6	5138.1	8.6376	0.15098	4457.5	5136.9	8.5825	0.13587	4456.3	5135.7	8.5311
1300	0.18156	4674.3	5400.5	8.8100	0.16139	4673.1	5399.4	8.7549	0.14526	4672.0	5398.2	8.7055
<i>P</i> = 6.0 MPa (275.64°C)					<i>P</i> = 7.0 MPa (285.88°C)					<i>P</i> = 8.0 MPa (295.06°C)		
Sat.	0.03244	2589.7	2784.3	5.8892	0.02737	2580.5	2772.1	5.8133	0.02352	2569.8	2758.0	5.7132
300	0.03616	2667.2	2884.2	6.0674	0.02947	2632.2	2838.4	5.9305	0.02426	2590.9	2785.0	5.7306
350	0.04223	2789.6	3043.0	6.3335	0.03524	2769.4	3016.0	6.2283	0.02995	2747.7	2987.3	6.1301
400	0.04739	2892.9	3177.2	6.5408	0.03993	2878.6	3158.1	6.4478	0.03432	2863.8	3138.3	6.3334
450	0.05214	2988.9	3301.8	6.7193	0.04416	2978.0	3287.1	6.6327	0.03817	2966.7	3272.0	6.5351
500	0.05665	3082.2	3422.2	6.8803	0.04814	3073.4	3410.3	6.7975	0.04175	3064.3	3398.3	6.7240
550	0.06101	3174.6	3540.6	7.0288	0.05195	3167.2	3530.9	6.9486	0.04516	3159.8	3521.0	6.8778
600	0.06525	3266.9	3658.4	7.1677	0.05565	3260.7	3650.3	7.0894	0.04845	3254.4	3642.0	7.0206
700	0.07352	3453.1	3894.2	7.4234	0.06283	3448.5	3888.3	7.3476	0.05481	3443.9	3882.4	7.2312
800	0.08160	3643.1	4132.7	7.6566	0.06981	3639.5	4128.2	7.5822	0.06097	3636.0	4123.8	7.5173
900	0.08958	3837.8	4375.3	7.8727	0.07669	3835.0	4371.8	7.7991	0.06702	3832.1	4368.3	7.7351
1000	0.09749	4037.8	4622.7	8.0751	0.08350	4035.3	4619.8	8.0020	0.07301	4032.8	4616.9	7.9384
1100	0.10536	4243.3	4875.4	8.2661	0.09027	4240.9	4872.8	8.1933	0.07896	4238.6	4870.3	8.1300
1200	0.11321	4454.0	5133.3	8.4474	0.09703	4451.7	5130.9	8.3747	0.08489	4449.5	5128.5	8.3115
1300	0.12106	4669.6	5396.0	8.6199	0.10377	4667.3	5393.7	8.5475	0.09080	4665.0	5391.5	8.4342
<i>P</i> = 9.0 MPa (303.40°C)					<i>P</i> = 10.0 MPa (318351.06°C)					<i>P</i> = 12.5 MPa (327.89°C)		
Sat.	0.02048	2557.8	2742.1	5.6772	0.018026	2544.4	2724.7	5.6141	0.013495	2505.1	2673.8	5.4324
325	0.02327	2646.6	2856.0	5.8712	0.019861	2610.4	2809.1	5.7568	0.016126	2624.6	2826.2	5.7118
350	0.02580	2724.4	2956.6	6.0361	0.02242	2699.2	2923.4	5.9443	0.02000	2789.3	3039.3	6.0117
400	0.02993	2848.4	3117.8	6.2854	0.02641	2832.4	3096.5	6.2120	0.02299	2912.5	3199.8	6.2119
450	0.03350	2955.2	3256.6	6.4844	0.02975	2943.4	3240.9	6.4190	0.02560	3021.7	3341.8	6.4318
500	0.03677	3055.2	3386.1	6.6576	0.03279	3045.8	3373.7	6.5966	0.02801	3125.0	3475.2	6.6390
550	0.03987	3152.2	3511.0	6.8142	0.03564	3144.6	3500.9	6.7561	0.03029	3225.4	3604.0	6.7310
600	0.04285	3248.1	3633.7	6.9589	0.03837	3241.7	3625.3	6.9029	0.03248	3324.4	3730.4	6.9118
650	0.04574	3343.6	3755.3	7.0943	0.04101	3338.2	3748.2	7.0398	0.03460	3422.9	3855.3	7.0336
700	0.04857	3439.3	3876.5	7.2221	0.04358	3434.7	3870.5	7.1687	0.03869	3620.0	4103.6	7.2365
800	0.05409	3632.5	4119.3	7.4596	0.04859	3628.9	4114.8	7.4077	0.04267	3819.1	4352.5	7.582
900	0.05950	3829.2	4364.8	7.6783	0.05349	3826.3	4361.2	7.6272	0.04658	4021.6	4603.8	7.7337
1000	0.06485	4030.3	4614.0	7.8821	0.05832	4027.8	4611.0	7.8315	0.05045	4228.2	4858.8	7.965
1100	0.07016	4236.3	4867.7	8.0740	0.06312	4234.0	4865.1	8.0237	0.05430	4439.3	5118.0	8.0337
1200	0.07544	4447.2	5126.2	8.2556	0.06789	4444.9	5123.8	8.2055	0.05813	4654.8	5381.4	8.217
1300	0.08072	4662.7	5389.2	8.4284	0.07265	4460.5	5387.0	8.3783				

SI  
T °C

## Ideal-gas properties of air

<i>T</i>	<i>h</i>	<i>u</i>	<i>s</i> <sup>o</sup>	<i>T</i>	<i>h</i>	<i>u</i>	<i>s</i> <sup>o</sup>
K	kJ/kg	kJ/kg	kJ/kg · K	K	kJ/kg	kJ/kg	kJ/kg · K
200	199.97	0.3363	142.56	1707.0	1.29559	580	586.04
210	209.97	0.3987	149.69	1512.0	1.34444	590	596.52
220	219.97	0.4690	156.82	1346.0	1.39105	600	607.02
230	230.02	0.5477	164.00	1205.0	1.43557	610	617.53
240	240.02	0.6355	171.13	1084.0	1.47824	620	628.07
250	250.05	0.7329	178.28	979.0	1.51917	630	683.63
260	260.09	0.8405	185.45	887.8	1.55848	640	649.22
270	270.11	0.9590	192.60	808.0	1.59634	650	659.84
280	280.13	1.0889	199.75	738.0	1.63279	660	670.47
285	285.14	1.1584	203.33	706.1	1.65055	670	681.14
290	290.16	1.2311	206.91	676.1	1.66802	680	691.82
295	295.17	1.3068	210.49	647.9	1.68515	690	702.52
300	300.19	1.3860	214.07	621.2	1.70203	700	713.27
305	305.22	1.4686	217.67	596.0	1.71865	710	724.04
310	310.24	1.5546	221.25	572.3	1.73498	720	734.82
315	315.27	1.6442	224.85	549.8	1.75106	730	745.62
320	320.29	1.7375	228.42	528.6	1.76690	740	756.44
325	325.31	1.8345	232.02	508.4	1.78249	750	767.29
330	330.34	1.9352	235.61	489.4	1.79783	760	778.18
340	340.42	2.149	242.82	454.1	1.82790	780	800.03
350	350.49	2.379	250.02	422.2	1.85708	800	821.95
360	360.58	2.626	257.24	393.4	1.88543	820	843.98
370	370.67	2.892	264.46	367.2	1.91313	840	866.08
380	380.77	3.176	271.69	343.4	1.94001	860	888.27
390	390.88	3.481	278.93	321.5	1.96633	880	910.56
400	400.98	3.806	286.16	301.6	1.99194	900	932.93
410	411.12	4.153	293.43	283.3	2.01699	920	955.38
420	421.26	4.522	300.69	266.6	2.04142	940	977.92
430	431.43	4.915	307.99	251.1	2.06533	960	1000.55
440	441.61	5.332	315.30	236.8	2.08870	980	1023.25
450	451.80	5.775	322.62	223.6	2.11161	1000	1046.04
460	462.02	6.245	329.97	211.4	2.13407	1020	1068.89
470	472.24	6.742	337.32	200.1	2.15604	1040	1091.85
480	482.49	7.268	344.70	189.5	2.17760	1060	1114.86
490	492.74	7.824	352.08	179.7	2.19876	1080	1137.89
500	503.02	8.411	359.49	170.6	2.21952	1100	1161.07
510	513.32	9.031	366.92	162.1	2.23993	1120	1184.28
520	523.63	9.684	374.36	154.1	2.25997	1140	1207.57
530	533.98	10.37	381.84	146.7	2.27967	1160	1230.92
540	544.35	11.10	389.34	139.7	2.29906	1180	1254.34
550	555.74	11.86	396.86	133.1	2.31809	1200	1277.79
560	565.17	12.66	404.42	127.0	2.33685	1220	1301.31
570	575.59	13.50	411.97	121.2	2.35531	1240	1324.93